

2429800000001-16

www.weidmueller.com

Deutsche Version:
siehe Vorderseite

Energy Meter 330

Quick Guide

Supplement to the operating manual

- Installation
- Commissioning
- Settings

Energy Meter 330

PRG

MkWh

MkVAh

CTVT

K1

K2

U1

U2

U3

U4

U5

U6

U7

U8

U9

U10

CTVT

K1

K2



http://wmp.eu/242541

Weidmüller Interface GmbH & Co. KG

Klingenbergstraße 16

D-32758 Detmold

+49 5231 14-0

+49 5231 14-292083

info@weidmueller.de

Weidmüller

1

General

This "Quick guide" does not replace the operating manual. First, please read and ensure that you understand the operating manual that accompanies the product.

Disclaimer

The observance of the information products for the devices is a prerequisite for safe operation and to achieve the stipulated performance characteristics and product characteristics. Weidmüller Interface GmbH & Co. KG accepts no liability for injuries to personnel, property damage or financial losses arising due to a failure to comply with the information products. Ensure that your information products are accessible and legible.

Further information can be found on our website www.weidmueller.de.

Copyright notice

© 2016 - Weidmüller Interface GmbH & Co. KG - Detmold. All rights reserved. Duplication, editing, distribution and any form of exploitation, also as excerpts, is prohibited.

Subject to technical amendments

Note that this document may not always be updated at the same time as technological developments. Information and specifications may change. Please check for the latest version at www.weidmueller.de.

Disposal

Please observe national regulations! If disposing of individual parts, please dispose of them in accordance with their nature and existing country-specific regulations, for example as:

- Electrical scrap
- Plastics
- Metals

Or, task a certified disposal business with the scrapping.

Relevant laws, applied standards and directives

The laws, standards and directives for the device applied by Weidmüller Interface GmbH & Co. KG can be found in the declaration of conformity.

2

Safety

Safety information

The "Quick guide" does not represent a full listing of all necessary safety measures required for safe operation of the device. Certain operating conditions may require further measures. The "Quick guide" contains information that you must observe for your own personal safety and to avoid damage to property.

Symbols used:

 This symbol is used as an addition to the safety instructions and warns of an electrical hazard.

 This symbol is used as an addition to the safety instructions and warns of a potential hazard.

 This symbol with the word **NOTE!** describes:

- Procedures that do not entail any danger of injury.
- Important information, procedures or handling steps.

Safety instructions are highlighted with a warning triangle and shown as follows, depending on the degree of hazard:

**DANGER!**

Indicates an immediately threatening hazard that leads to serious or even fatal injuries.

**WARNING!**

Indicates a potentially hazardous situation that could lead to serious or even fatal injuries.

**CAUTION!**

Indicates a potentially hazardous situation that could lead to minor injuries or damage to property.

Measures for safety

When operating electrical devices certain parts of these devices inevitably carry dangerous voltages. This could result in serious bodily injury or damage to property if not handled properly:

- Before establishing electrical connections to the device, earth it at the ground wire connection if there is one.
- Hazardous voltages may arise in all circuit parts that are connected to the power supply.
- Even after disconnecting the supply voltage, there may still be hazardous voltages present in the device (capacitor storage).

- Do not operate equipment with current transformer circuits when open.
- Do not exceed the limit values stipulated in the operating manual - even during testing or commissioning.
- Observe the safety and warning information in the documents that belong to the devices!

Qualified personnel

In order to avoid injuries to personnel and property damage, only qualified personnel with electrical training are permitted to work on the devices with knowledge:

- of the national regulations for accident prevention
- of safety standards
- of installation, commissioning and operation of the device.

Proper use

The device is

- intended for installation in switch cabinets and small installation distributors (please observe step 3 "Installation").
- not intended for installation in vehicles!

The use of the device in mobile equipment is considered to be non-standard environmental conditions and is therefore only permitted after separate agreement.

- not intended for installation in environments with hazardous oils, acids, gases, vapours, dusts, radiation, etc.

The prerequisites of faultless, safe operation of this device are proper transport and proper storage, set-up, installation, operation and maintenance.


3

Brief description of device


The Energy Meter 330 is a universal measurement device for low voltage and medium voltage distribution systems, which

- measures and calculates electrical variables such as voltage, current, power, etc. in building installations, on distribution units, circuit breakers and busbar trunking systems.

Connections for the measurement and supply voltage



Connections for the current measurement




NOTE!

More detailed information on the device functions, data and installation can be found in the operating manual.

Installation

Install the Energy Meter 330 in the weather-protected front panel of switch cabinets.



Cut-out size for the device:
92^{+1.5} x 92^{+1.5} mm

Ensure!

- Adequate ventilation
- The device is installed vertically!
- Observance of clearance to adjacent components!

Fig. Installation situation, rear view

**CAUTION!**

Damage to property due to disregard of the installation instructions

Disregard of the installation instructions can damage or destroy your device.

Ensure that you have enough air circulation in your installation environment and in the event of high environmental temperatures, provide cooling if necessary.

4

Connecting the supply voltage

The device derives its supply voltage from the measurement voltage L1 - N.

Connect phase L1 and the neutral conductor N (230 V/400 V) so that the voltage lies within the measurement and supply range.

**WARNING!**

Danger of injury due to electrical voltage!

Serious bodily injury or death can result from:

- Contact with bare or stripped live wires.
- Device inputs that are dangerous to touch.

Render the system free of voltage before starting work! Check the system is free of electrical energy!

**CAUTION!**

Damage to property due to disregard of the connection conditions or impermissible overvoltage


Your device can be damaged or destroyed by a failure to comply with the connection conditions or by exceeding the permissible voltage range. Before connecting the device to the supply voltage, please check:

- Voltage and frequency correspond to the details on the ratings plate! Limit values stipulated in the operating manual have been complied with!
- In building installations, the supply voltage must be protected with a UL approved circuit breaker / a fuse (2-10 A)!
- The isolation device
 - must be installed near the device and in a location that is easily accessible for the user.
 - must be labelled to identify the respective device.
- Do not tap the supply voltage from the voltage transformer.
- Provide a fuse for the neutral conductor if the neutral conductor terminal of the source is not grounded.


5

Mains systems

Mains systems and max. rated voltages (DIN EN 61010-1/A1):



Three-phase, four-conductor system with earthed neutral conductor



Three-phase, four-conductor system with non-earthed neutral conductor (IT networks)

Standard version:
U_N-N / U_L-L
255 VLN / 442 VLL

Standard version:
U_N-N / U_L-L
255 VLN / 442 VLL

The device can be used in

- 2, 3 and 4 conductor networks (TN, TT and IT networks)
- in residential and industrial applications.

6

Voltage measurement

The device has 3 voltage measurement inputs and is suitable for various different connection variants (see step 8).

**CAUTION!**

Danger of injury or damage to the device

Disregard of the connection conditions for the voltage measurement inputs can result in injuries or to the device being damaged. For this reason, note that:

- The voltage measurement inputs
 - are not connected to DC voltage.
 - are equipped with a suitable, labelled fuse and isolation device (alternative: circuit breaker) located nearby.
 - are dangerous to touch.
- Voltages that exceed the allowed network rated voltages must be connected via a voltage transformer.
- Measured voltages and measured currents must derive from the same network.

NOTE!

A (2-10 A) circuit breaker can be used as an alternative to a fuse and isolating device.

The voltage measurement inputs are designed for:

- Measurement in low voltage networks where rated voltages of 230 VAC phase to earth and 400 V phase to phase can occur.
- Surge voltages of overvoltage category CATIII.

NOTE!

If the measurement range is exceeded, the measurement device display shows "Err". Further information on this can be found in the operating manual.

7

Current measurement

The device

- is only approved for measuring current with a current transformer.
- is intended for the connection of current transformers with secondary currents of ..1 A and ..5 A.
- has the current transformer ratio set to 5/5 A as standard.
- does not measure DC.

**WARNING!**

Danger of injury due to electrical voltage!

Serious bodily injury or death can result from:

- Contact with bare or stripped live wires.
- Current measurement inputs on the device and on the current transformer that are dangerous to touch.

Render the system free of voltage before starting work! Check the system is free of electrical energy!

Earth the system! Use the earth connection points with earthing symbols for this! Earth the secondary windings of current transformers and all of the metal parts of the transformer that could be touched!

**WARNING!**

Danger of injury due to high currents and high electrical voltages!


Current transformers operating with an open secondary circuit (high voltage peaks) can result in serious or even fatal injuries. Avoid open operation of the current transformers - short-circuit unloaded transformers!

NOTE!


Further information on current data and current transformer data can be found in the operating manual.

8


Connection variants




Connection variant 1
Measurement in the three-phase, four-conductor system with 3 current transformers.




Connection variant 2
Measurement in the three-phase, four-conductor system with 2 current transformers.




Connection variant 3
Measurement in the three-phase, four-conductor system with 3 voltage transformers and 3 current transformers.




Connection variant 4
Measurement in the three-phase, four-conductor system with 3 voltage transformers and 2 current transformers.




Connection variant 5
Measurement in the three-phase, three-conductor system with 3 voltage transformers and 3 current transformers.



Connection variant 6
Measurement in the three-phase, three-conductor system with 3 voltage transformers and 2 current transformers.



Connection variant 7
Measurement in the IT network with 3 current transformers.



Connection variant 8
Measurement in the IT network with 3 voltage transformers and 3 current transformers.

9

The most important technical data

Measurement and supply voltage	
Installation overvoltage category	300 V CAT III (standard version)
Measurement inputs	1 measurement/sec.
Measurement rate	45 Hz
Rated surge voltage	4 kV
Signal frequency	45 Hz to 1000 Hz
Sampling rate	2.5 kHz/3.0 kHz (main frequency) 50 Hz/60 Hz
Supply voltage L-N	196 to 255 V AC
Measurement range	L-N 50 V - 255 V, L-L 86 V - 442 V
Back-up fuse	2 to 10 A (medium time delay)
Frequency range of the fundamental oscillation	45 Hz to 65 Hz
Power consumption, phase (L-N)	approx. 0.1 VA per phase

**NOTE!**

Further technical data can be found in the operating manual for the device.

Current measurement:	
Power consumption	approx. 0.2 VA
Nominal current at ..5 A / ..1 A	5 A / 1 A
Triggering current	20 mA
Limit current at ..5 A	6 A (sinusoidal)
Limit current at ..1 A	1.2 A (sinusoidal)
Overloading	150 A for 2 sec.
Precision class for the working measurement	Class 2

**NOTE!**

Further technical data can be found in the operating manual for the device.

10

Controls and button functions

The device is operated with buttons 1 and 2, whereby the following distinctions are made:

- Short press (button 1 or 2):
 - Next step (+1).
 - Longer press (button 1 or 2): Previous step (-1).

The device differentiates between display and programming mode.

Display mode

- Buttons 1 and 2 can be used to scroll between the measured value indications.
- The measured value indication shows up to 3 measured values.

Programming mode


- Hold buttons 1 and 2 depressed simultaneously for 1 second to change between display mode and programming mode. The text **PRG** appears in the display.
- Configure the necessary settings for the operation of the device in programming mode.
- The programming mode can be protected with a user password.
- Button 2 switches between the programming menus, amongst other things:
 - Current transformer
 - Voltage transformer
 - Outputs K1 and K2

**NOTE!**

Changes are only applied after exiting the programming mode.

**NOTE!**

More detailed information on the operation, display of measured values, menus and button functions can be found in the operating manual for your device.



Max. value, HT/reference
Min. value NT/delivery
Mean value
Programming mode
Summation measurement
Phase conductor-
Phase conductor
Password
CT: Current transformer
VT: Voltage transformer
K1: Output 1
K2: Output 2
Button 2
Button 1

11

Programming current transformers

- Switch to programming mode.
- The symbols for Programming mode **PRG**, and for the current transformer **CT** appear.
- Press button 1 - the first digit of the input field for the primary current flashes.
- Use button 2 to select the value of the 1st. digit.
- Use button 1 to change to the 2nd. digit.
- Use button 2 to select the value of the 2nd. digit.
- Use button 1 to change to the 3rd. digit.
- Use button 2 to select the value of the 3rd. digit.
- Confirm with button 1.
- The complete number flashes.
- Use button 2 to select the decimal place and thus the unit of the primary current.
- Confirm with button 1.
- The input range of the secondary current flashes.
- Set the secondary current (value 1 A or 5 A) with button 2 (standard setting ..5A).
- Confirm with button 1.
- Exit programming mode by simultaneously pressing buttons 1 and 2 (1 sec.). Use button 2 to change to the input field for the voltage transformer.




Fig. "Current transformer" input field

**NOTE!**

- Changes are only applied after exiting the programming mode.
- Further information on current transformers and current transformer ratios can be found in the operating manual.

12

Programming the voltage transformer

- Switch to programming mode.
- The symbols for Programming mode **PRG**, and for the voltage transformer **VT** appear.
- Press button 1 - the first digit of the input field for the primary voltage flashes.
- Use button 2 to select the value of the 1st. digit.
- Use button 1 to change to the 2nd. digit.
- Use button 2 to select the value of the 2nd. digit.
- Use button 1 to change to the 3rd. digit.
- Use button 2 to select the value of the 3rd. digit.
- Confirm with button 1.
- The complete number flashes.
- Use button 2 to select the decimal place and thus the unit of the primary voltage.
- Confirm with button 1.
- Exit programming mode by simultaneously pressing buttons 1 and 2 (1 sec.). Use button 2 to change to the programming mode for outputs K1 and K2.




Fig. "Voltage transformer" input field

"Secondary voltage transformer" settings		
Designation	Setting range	Standard setting
Rating plate 196 - 255 V	400 V (non-adjustable)	400 V

**NOTE!**

- Changes are only applied after exiting the programming mode.
- Further information on voltage transformers and voltage transformer ratios can be found in the operating manual.

Weidmüller