


IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product	Terminal blocks for copper conductors
Name and address of the applicant	Weidmüller Interface GmbH & Co. KG Klingenbergstrasse 26, 32758 Detmold Germany
Name and address of the manufacturer	Weidmüller Interface GmbH & Co. KG Klingenbergstrasse 26, 32758 Detmold Germany
Name and address of the factory	<input checked="" type="checkbox"/> Additional information on page 2 Weidmüller Interface GmbH & Co. KG Klingenbergstrasse 26, 32758 Detmold Germany
Note: <i>When more than one factory, please report on page 2</i>	
Ratings and principal characteristics	ZTR 2.5: 2,5 mm ² , 20 A, 500 V, 6 kV ZTR 2.5/SI: terminal block 2,5 mm ² , 6,3 A, 500 V, 6 kV Fuse holder part: 250 V, 4 kV BEST/D:250 V, 1 A ZSI 2.5, ZSI 2.5/LD 250AC: 2,5 mm ² , 6,3 A, 500 V, 6 kV Fuse holder part: 250 V, 4 kV ZTR 2.5 O.TNHE: 2,5 mm ² , 500 V, 6 kV ZTL 6, ZTL 6 STB: 6 mm ² , 41 A, 800 V, 8 kV
Trademark (if any)	Weidmüller
Customer's Testing Facility (CTF) Stage used	
Model / Type Ref.	ZSI 2.5, ZSI 2.5/LD 250AC, ZTR 2.5, ZTR 2.5 O.TNHE, ZTR 2.5/SI, ZTL 6, ZTL 6 STB, ZTR 2.5+BEST/D
Additional information (if necessary may also be reported on page 2)	<input type="checkbox"/> Additional information on page 2 This CB test certificate replaces CB test certificate NL-46871 issued on 2017-07-10, due to the fact that factories are added.
A sample of the product was tested and found to be in conformity with	IEC 60947-7-1:1989, IEC 60947-7-3:2009
As shown in the Test Report Ref. No. which forms part of this Certificate	2243850.52, 2243850.53, 2243850.54, 2243850.55

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.
Meander 1051, NL-6825 MJ Arnhem, Netherlands

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

Additional factory

Weidmüller Interface Romania S. R. L
Strada 66
437345 Tautii Magheraus
Romania

Weidmuller Lanskrout, s.r.o.
Dobrovskeho 1115
56301 Lanskrout
Czech Republic

Weidmüller Interface (Suzhou) Co. Ltd.
No. 58 Shilin Road
215151 Suzhou
China

EWE s.r.o.
Trebovska 570
562 03 Usti Nad Orlici
Czech Republic

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.
Meander 1051, NL-6825 MJ Arnhem, Netherlands

