

# CERTIFICATE OF COMPLIANCE

**Certificate Number** E470829  
**Report Reference** E470829-20190224  
**Date** 2022-March-02

**Issued to:** Weidmueller Interface GmbH & Co. KG  
Klingenbergstrasse 26  
Detmold 32758 DE

**This is to certify that representative samples of** POWER CIRCUIT AND MOTOR-MOUNTED APPARATUS  
FOR USE IN HAZARDOUS LOCATIONS

See Addendum Page for Product Designation(s).

Have been investigated by UL in accordance with the  
Standard(s) indicated on this Certificate.

**Standard(s) for Safety:** See Addendum Page for Standard(s)

**Additional Information:** See the UL Online Certifications Directory at  
<https://iq.ulprospector.com> for additional information

This Certificate of Compliance does not provide authorization to apply the UL Mark. Only the UL Follow-Up Services Procedure provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



# CERTIFICATE OF COMPLIANCE

**Certificate Number** E470829  
**Report Reference** E470829-20190224  
**Date** 2022-March-02

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements

USL/CNL – Open-type Switch Mode Power Supply, Models PRO TOP3 480W 24V 20A, PRO TOP3 480W 24V 20A CO, PRO TOP3 480W 48V 10A and PRO TOP3 480W 48V 10A CO for use in Class I, Division 2, Groups A, B, C and D Hazardous Locations.

Communication modules of PRO COM series:

Accessory model cat. no. PRO COM CAN OPEN, PRO COM CAN OPEN EX, PRO COM CAN J1939 RIV, PRO COM IO-LINK, PRO COM DISPLAY 7S for use with Open Type Power Supplies for use in Class I, Division 2, Groups A, B, C and D Hazardous Locations.

Standard(s):

UL 121201 Nonincendive Electrical Equipment for Use in Class I and II, Division 2 and Class III, Divisions 1 and 2 Hazardous (Classified) Locations,  
CSA C22.2 NO. 213 Nonincendive Electrical Equipment for Use in Class I and II, Division 2 and Class III, Divisions 1 and 2 Hazardous (Classified) Locations.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

