

CERTIFICATE OF COMPLIANCE

Certificate Number 20170130-E470829
Report Reference E470829-20141017
Issue Date 2017-JANUARY-30

Issued to: Weidmueller Interface GmbH & Co Kg
KLINGENBERGSTR 16
32758 DETMOLD GERMANY

**This is to certify that
representative samples of**

POWER CIRCUIT AND MOTOR-MOUNTED APPARATUS
FOR USE IN HAZARDOUS LOCATIONS

Class I, Division 2, Groups A, B, C and D Hazardous
Locations. Switching Power Supplies, Models PRO MAX
120W 12V 10A and PRO MAX 120W 24V 5A.

Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.

Standard(s) for Safety:

ANSI/ISA 12.12.01-2013, Nonincendive Electrical
Equipment for Use in Class I and II, Division 2 and Class III,
Divisions 1 and 2 Hazardous (Classified) Locations,
CAN/CSA C22.2 No. 213-M1987, Non-incendive Electrical
Equipment for Use in Class I, Division 2 Hazardous
Locations

Additional Information:

See the UL Online Certifications Directory at
www.ul.com/database for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's
Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please
contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

