

# CERTIFICATE OF COMPLIANCE

**Certificate Number** 20170130-E470829  
**Report Reference** E470829-20141015  
**Issue Date** 2017-JANUARY-30

**Issued to:** Weidmueller Interface GmbH & Co Kg  
KLINGENBERGSTR 16  
32758 DETMOLD GERMANY

**This is to certify that  
representative samples of**

POWER CIRCUIT AND MOTOR-MOUNTED APPARATUS  
FOR USE IN HAZARDOUS LOCATIONS

Class I, Division 2, Groups A, B, C and D Hazardous  
Locations. Switching Power Supply, Model PRO MAX3  
120W 24V 5A.

Have been investigated by UL in accordance with the  
Standard(s) indicated on this Certificate.

**Standard(s) for Safety:**


ANSI/ISA 12.12.01-2013, Nonincendive Electrical  
Equipment for Use in Class I and II, Division 2 and Class III,  
Divisions 1 and 2 Hazardous (Classified) Locations,  
CAN/CSA C22.2 No. 213-M1987, Non-incendive Electrical  
Equipment for Use in Class I, Division 2 Hazardous  
Locations.

**Additional Information:**

See the UL Online Certifications Directory at  
[www.ul.com/database](http://www.ul.com/database) for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's  
Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program  
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please  
contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

