

## IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

## CB TEST CERTIFICATE

## Product

Terminal block for copper conductor

## Name and address of the applicant

Weidmüller Interface GmbH & Co. KG  
Klingenbergstrasse 16 / 26, 32758 Detmold  
Germany

## Name and address of the manufacturer

Weidmüller Interface GmbH & Co. KG  
Klingenbergstrasse 16 / 26, 32758 Detmold  
Germany

## Name and address of the factory

Weidmüller Interface GmbH & Co. KG  
Klingenbergstrasse 16 / 26, 32758 Detmold  
Germany*Note: When more than one factory, please report on page 2*☒ [Additional information on page 2](#)

## Ratings and principal characteristics

A2T 4 DT-FT...  
4 mm<sup>2</sup>; 20 A; Uimp 6 kV; Ui 250 VA2T 4 FS-FT...  
4 mm<sup>2</sup>; 6,3 A; Ui 500 V (adjacent terminal blocks) Ui 250 V (inside fuse carrier and terminal block base)  
Uimp 6 kV (adjacent terminal blocks) Uimp 4 kV (inside fuse carrier and terminal block)  
Fuse link size: 5x20 mm; also with indicator light with rated voltage 36 V up to 250 V

## Trademark / Brand (if any)

**Weidmüller** 

Weidmüller

## Customer's Testing Facility (CTF) Stage used

## Model / Type Ref.

A2T 4 DT-FT, A2T 4 DT-FT-PE, A2T 4 FS-FT-PE BK,  
A2T 4 FS-FT BK, A2T 4 FS-FT-PE 10-36V BK, A2T 4 FS-FT-PE 30-70V BK,  
A2T 4 FS-FT-PE 60-150V BK, A2T 4 FS-FT-PE 100-250V BK,  
A2T 4 DT-FT w/o DTLV, A2T 4 DT-FT-PE w/o DTLV

## Additional information (if necessary may also be reported on page 2)

Types A2T 4 DT-FT w/o DTLV and A2T 4 DT-FT-PE w/o DTLV are used with accessory type AFTC

☐ [Additional information on page 2](#)

## A sample of the product was tested and found to be in conformity with

IEC 60947-7-1:2009, IEC 60947-7-2:2009, IEC 60947-7-3:2009

## As shown in the Test Report Ref. No. which forms part of this Certificate

2270442.50; 2270442.51; 2270442.52

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.  
Meander 1051  
Arnhem, 6825 MJ  
Netherlands  


Date: 2024-06-03

Signature: Henk Barends

IEC

IECEE



TM

Ref. Certif. No.

NL-90616

#### Additional factory

EWE s.r.o.  
Trebovska 570  
Usti Nad Orlici, 562 03  
Czech Republic

Weidmüller Interface (Suzhou) Co. Ltd.  
No. 58 Shilin Road  
Suzhou, 215151  
China

Weidmüller Interface Romania S. R. L.  
Strada 66  
Tautii Magheraus, 437345  
Romania

Weidmuller Lanskroun, s.r.o.  
Dobrovskeho 1115  
Lanskroun, 56301  
Czech Republic

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.  
Meander 1051  
Arnhem, 6825 MJ  
Netherlands



Date: 2024-06-03

Signature: Henk Barends