



Certificate of Conformity



Number CoC-2219236-01 Project number 2219236 Page 1 of 3

Issued by : NMi Certin B.V.

Hugo de Grootplein 1 314 EG Dordrecht The Netherlands

Applicant : Weidmüller Interface GmbH & Co. KG

Klingenbergstrasse 26

32758 Detmold Germany

Submitted : A meter embedding IEC 61000-4-30 class A Power Quality functions

Manufacturer : Weidmüller Type : EA 750

Characteristics : See page 2 and further

In accordance with : IEC 61000-4-30 Ed. 3 (2015)

"Electromagnetic Compatibility (EMC) – Part 4-30: Testing and measurement techniques – Power quality measurement methods"

IEC 62586-2 Ed. 2 (2017)

"Power quality measurement in power supply systems - Part 2: Functional

tests and uncertainty requirements"

Measurement class : IEC 61000-4-30 class A

The undersigned declares that the described product is tested according to the above mentioned standard and meet their requirements, based on a non-recurrent examination. The appertaining test data is presented in type evaluation report number NMi-1902605-01, granted by NMi Certin B.V.

(+)

NMi Certin B.V. 8 August 2019

C. Oosterman

Head Certification Board



NMi Certin B.V. Thijsseweg 11 2629 JA Delft The Netherlands T +31 88 636 2332 certin@nmi.nl www.nmi.nl This document is issued under the provision that no liability is accepted and that the applicant shall indemnify third-party liability.

Reproduction of the complete document only is permitted.













Number CoC-2219236-01 Project number 2219236 Page 2 of 3

IEC 61000-4-30 Power Quality functions tested

The following IEC 61000-4-30 measurement methods have been tested





Table 1 IEC 61000-4-30 Power Quality functions tested

IEC 62586-2 Clause	Parameter	IEC 61000-4-30 class	Comments
6.1 / 7.1	Power frequency	Α	50 and 60 Hz
6.2 / 7.2	Magnitude of supply voltage	Α	230 V and 57,7 V
6.3 / 7.3	Flicker	A	Class F3: 230 V, 60 Hz 120 V, 50 Hz
6.4 / 7.4	Supply voltage interruptions, dips and swells	A	50 and 60 Hz
6.5 / 7.5	Supply voltage unbalance	A	
6.6 / 7.6	Voltage harmonics	Α	
6.7 / 7.7	Voltage interharmonics	A	
6.8 / 7.8	Mains signalling voltages on the voltage supply	A	Method 2
6.9 / 7.9	Measurement of underdeviation and overdeviation parameters	A	
6.10 / 7.10	Flagging	A	
6.11 / 7.11	Clock uncertainty testing	Α	
6.12 / 7.12	Variation of external influence quantities	A	Temperature: -10°C +55°C
6.13 / 7.13	Rapid Voltage Changes (RVC)	A	
6.14 / 7.14	Magnitude of current	A	
6.15 / 7.15	Harmonic current	A —	
6.16 / 7.16	Interharmonic currents	A	
6.17 / 7.17	Current unbalance	A	
8	Calculation of measurement uncertainty and operating uncertainty	A	

A: compliance with class AS: compliance with class S---: Not implemented

The tests are performed in accordance with IEC 62586-2 edition 2 (2017).







Certificate of Conformity



Number CoC-2219236-01 Project number 2219236 Page 3 of 3



Characteristics of the measuring instrumentIn Table 2 the general characteristics of the measuring instrument are presented.

Table 2 General characteristics

Model	EA 750		
U_{din}	230 V _{LN} or 57,7 V _{LN}		
I _{nom}	3 A		
f_{nom}	50 Hz and 60 Hz		
Temperature	Rated range of operation: -10°C to +55°C		
Power supply range	95 240 VAC 50/60 Hz 48 110 VDC (52.17.011) 48 110 VAC 50/60 Hz 24 150 VDC (52.17.003)		
Software version	V 5.011		
Hardware version	100		
Environmental application	Fixed (F), Indoor (I)		







